



DANGER!

H314 Causes severe skin burns and eye damage.

H318 Causes serious eye damage.

Prevention:

P260 Do not breathe mist / vapors / spray.

P264 Wash thoroughly after handling.

P280 Wear protective gloves / eye protection / face protection.

Response:

P301+330+331 IF SWALLOWED: Rinse mouth. Do NOT induce vomiting.

P303+361+353 IF ON SKIN (or hair): Remove / Take off immediately all contaminated clothing. Rinse skin with water / shower.

P304+340 IF INHALED: Remove victim to fresh air and keep at rest in a position comfortable for breathing.

P305+351+338 IF IN EYES: Rinse cautiously with water for several minutes. Remove contact lenses if present and easy to do - continue rinsing.

P310 Immediately call a POISON CENTER or doctor / physician.

P363 Wash contaminated clothing before reuse.

Storage:

P405 Store locked up.

Disposal:

P501 Dispose of contents / container in accordance with local / national regulations.



(509)452-4476 (800)579-6832
2809 FRUITVALE BLVD.
YAKIMA, WASHINGTON, USA 98902

PHASE 1

BufferAC®

A LOW FOAM ACID CLEANING SOLUTION USED IN AQUEOUS SYSTEMS AS A BUFFER IN COMBINATION WITH CALCIUM HYPOCHLORITE

DIRECTIONS: AUTOMATED PUMPING SYSTEM: BUFFER AC IS SPECIFICALLY DESIGNED FOR USE WITH CALCIUM HYPOCHLORITE. PH METERING PUMP EQUIPMENT SHOULD BE SET BETWEEN 6.5 TO 7.5 BY A CERTIFIED U.S. SYNTEC TECHNICIAN. FREQUENT MONITORING OF DUMP TANK PH WITH PH STRIPS OR HANDHELD PH METER IS RECOMMENDED TO FURTHER VERIFY ACCURACY OF PH INJECTION EQUIPMENT. READINGS SHOULD BE TAKEN NEXT TO THE PH PUMP PROBE SEVERAL TIMES PER DAY. MANUAL ADDITION: START BY ADDING 1 QUART OF BUFFERAC PER 1000 GALLONS OF WATER. CHECK PH 5 MINUTES AFTER THE INITIAL ADDITION ADJUSTING TO ACHIEVE A 6.5 TO 7.5 PH. MEASUREMENTS SHOULD ALWAYS BE TAKEN BY PH STRIPS OR RECENTLY CALIBRATED PH METER.

INSTRUCCIONES: SISTEMA AUTOMÁTICO DE BOMBEO: BUFFER AC HA SIDO ESPECÍFICAMENTE DISEÑADO PARA SER UTILIZADO CON HIPOCLORITO DE CALCIO. EL EQUIPO DE BOMBA POR SUMINISTRO MEDIDO DEBE SER PREPARADO POR UN TÉCNICO AUTORIZADO POR U.S. SYNTEC PARA FIJARLO A UN PH ENTRE 6,5 Y 7,5. MONITOREAR EL PH DEL ESTANQUE CON TIRAS DE CONTROL DE PH O MEDIDORES PORTÁTILES DE PH PARA VERIFICAR CON EXACTITUD EL FUNCIONAMIENTO DEL SISTEMA DE INYECCIÓN DE PH. LA LECTURA DEBERÁ EFECTUARSE AL LADO DE LOS DISPOSITIVOS CAPTADORES DE PH VARIAS VECES AL DÍA. APLICACIÓN MANUAL: INICIE AGREGANDO 1 CUARTO DE GALÓN DE BUFFERAC POR CADA 1000 GALONES DE AGUA. VERIFICAR EL PH 5 MINUTOS DESPUÉS DE LA PRIMERA APLICACIÓN AGREGANDO EN PEQUEÑAS CANTIDADES HASTA LOGRAR UN PH ENTRE 6,5 A 7,5. SIEMPRE TOMÉ SUS MEDICIONES CON TIRAS DE CONTROL DE PH O CON UN MEDIDOR DE PH QUE HAYA SIDO PRE-CALIBRADO.

STORAGE: DO NOT ALLOW THIS PRODUCT TO FREEZE. STORE INSIDE AT TEMPERATURES BETWEEN 40°-100° F. (4.4°C - 37.7°C) WITH CAPS SECURED WHEN NOT IN USE.

ALMACENAMIENTO: NO PERMITA QUE ESTE PRODUCTO SE CONGEELE, ALMACENAR A TEMPERATURAS ENTRE 40° -100° F (4,4 °C - 37,7 °C) CON SUS RESPECTIVAS TAPAS ROSCA ASEGURÁNDOSE QUE ESTÉN DEBIDAMENTE INSTALADAS Y APRETADAS.

NON-WARRANTY: SINCE ACTUAL USE BY OTHERS IS BEYOND OUR CONTROL, NO WARRANTY, EXPRESSED OR IMPLIED, IS MADE BY U.S. SYNTEC CORPORATION, NOR DOES U.S. SYNTEC CORPORATION ASSUME ANY LIABILITY ARISING OUT OF THE USE BY OTHERS OF THE PRODUCT REFERRED HEREIN.

CONDICIONES DE LA GARANTIA: EN CONSECUENCIA QUE EL USO DE ESTE PRODUCTO POR TERCEROS ESTÁ FUERA DE NUESTRO CONTROL, U. S. SYNTEC CORPORATION NO EXTENDERÁ GARANTÍA ALGUNA, COMO TAMPOCO U.S. SYNTEC CORPORATION SE HARÁ RESPONSABLE POR EL USO DE ESTE PRODUCTO POR TERCEROS.



ERG 154



CONTAINER MUST BE EMPTIED, RINSED AND CAPPED BEFORE RETURNING TO U.S. SYNTEC CORP

LOT# 11 P1 BAC55 MD2958

55 GALLONS (208.19 LITERS) NET WT. 480 LBS.